



# CITY OF RIVERSIDE FIRE DEPARTMENT

## Incident Information Fact Sheet



**Incident Name:** Larchwood Place

**Incident Location:** 3700 Block of Larchwood Place

**Type of Incident:** Natural Gas Leak

**Incident Number:** #16-017718 FINAL

**Date Reported:** 06/27/2016

**Time Reported:** 9:33 AM

**Fatalities:** 0 **Critical:** 0 **Moderate:** 0 **Minor:** 0 **Non Injury:** 0

**Transported Ground Ambulance(s):** 0

**Loss:** \$0

**Save:** \$0

**Cause:** Construction

**Control Time:** 06/27/2016 1205

**Evacuations:** No

**Evacuation Comments:**

### RESOURCES ASSIGNED

**Fire Fighters:** 4

**Engine Companies:** 1

**Truck Companies:** 0

**Specialized Equipment:**

**Overhead Personnel:** 1

**Ambulance(s):** 0

**Water Tenders:** 0

**Utilities:** Yes

**Red Cross:** No

**Displaced Persons:** No

### CURRENT SITUATION

*(Recent updates are posted at the top of Current Situation)*

The City of Riverside Fire Department is on scene in the 3700 block of Larchwood Place for a natural gas leak from a natural gas line. RPU Water were constructing a trench across the street and accidentally struck the Natural Gas Line. RPU was installing a new fire hydrant. Twelve residential houses are being advised to shelter in place or evacuate as precaution. The ruptured line is a 2" distribution Natural Gas Line. The residents who are in the immediate area have been notified. EOC has been notified as precaution. RCC is not affected by the gas leak for their distribution. Larchwood Place has been closed to traffic from Magnolia to Riverside Ave. SOCAL Gas has been mitigated the ruptured line. Residents are no longer sheltering in place. RPU to remain on scene working on the street.

### COOPERATING AGENCIES

RPU, Riverside Streets, So. Cal Gas Co.